



QUADRUPLE SERVICE MANIFOLD

NOT TO SCALE

NOTES:

1. USE GATE VALVE SERVICE CONNECTION SEE DETAIL 701.
2. FOR 5/8" x 3/4" METER SETTERS, 2" MANIFOLD SHALL BE 12" LONG.
FOR 1" METER SETTERS, 2" MANIFOLD SHALL BE 12" LONG.
3. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD SIZE SHALL BE 3/4" FROM BUSHING AT TEE.
FOR 1" METER SETTERS, MANIFOLD SIZE SHALL BE 1" FROM BUSHING AT TEE.
4. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD SHALL BE 12" LONG.
FOR 1" METER SETTERS, MANIFOLD SHALL BE 6" LONG.
5. FOR 5/8" x 3/4" METER SETTERS, USE 2-17"x30" METER BOXES AS SHOWN.
FOR 1" METER SETTERS, USE INDIVIDUAL METER BOXES SIMILAR TO THE SINGLE SERVICE DETAIL 703.
6. THE METER BOXES SHALL BE CENTERED OVER THE METER SETTER ASSEMBLIES AS SHOWN.

APPROVED: LYNN ARAKAKI

REV. DATE: SEPT. 24, 1999

WATER/WASTEWATER DIVISION



STANDARD DETAILS

QUADRUPLE SERVICE MANIFOLD

FILE | SD703C.DWG | DRAWING NO. | **703C**